



ICT AIAPL JV LLP

Consultancy Services as Authority's Engineer of Supervision of Construction of (i) Connecting Road from Z-Morh Tunnel to Zojila Tunnel and (ii) 14.150 km long bi-directional tunnel across Zojila Pass on Sonamarg-Kargil Section of NH-01 on EPC Mode in the Union Territories of Jammu & Kashmir and Ladakh

ICT/Zojila/MEIL/2022/ 472

23 June, 2022

Project Manager
M/s Megha Engineering and Infrastructure Ltd.
Hotel Grand Hayatt,
Gagangeer-Sonamarg,
District: Ganderbal,
UT of J&K
Email: meilplanning.zojila@gmail.com

Sub: "Construction of (i) Connecting road from Z- Morh Tunnel to Zojila Tunnel and (ii) 14.150 Km long bi-directional tunnel across Zojila pass on Sonamarg Kargil section of NH-01 on EPC mode in the Union Territories of Jammu & Kashmir and Ladakh". Reg - "Approval of Construction Material Source- Technicol India Pvt Ltd".

Reference- NHIDCL/J&K/Zojila Tunnel-EPC/ NH-1/ R-1/ 196697/ 2022-2023/919 dated 20th June2022
NHIDCL/RO –SGR/Zojila/ 2021-22/ 301 dated 20th May2022
NHIDCL/Ro-SGR/Zojila/2021-22/ 305 dated 10th June2022
MEIL/Zojila/SITE/2022-23/472 dated 26th April 2022

Dear Sir,

With reference to above cited subject regarding submission of PVC-P membrane source approval of M/s Technicol India Pvt Ltd.

The credential of M/s Technicol India Pvt Ltd for PVC-P water proofing membrane has been reviewed as per Contract Agreement Schedule –D and other relevant European standard guideline and found satisfactory.

Hence, approval of source M/s Technicol India pvt Ltd for PVC-P water proofing membrane is hereby accorded to procure the consignment of PVC-P water proofing membrane in the project as per letter no NHIDCL / PMU-SMG/Zojila/ AE/ 2021-22 /78 dated 21.06.2022.

After arrival of consignment PVC-P water proofing membrane at the site and further jointly sample shall be collected in presence of our representative and to be sent to approved NABL laboratory for testing as per Technical Specification of Contract agreement schedule –D.

PVC-P membrane shall be used only after confirmation of the satisfactory test result.

Thanking you.

Yours Truly,

For ICT- AIAPL (JV) LLP

Yousef Es'hagpour
Team Leader

Copy forwarded to:

1. General Manager (P) PMU- Sonamarg for kind information. nhidcl.sonamarg@gmail.com
2. Authority Engineer ICT AIAPL Head Office for kind information. ap.misra@ictonline.com
3. RE Tunnel for information.
4. Mr. K.K. Gupta, SQME for information & necessary action. kkguptatdl@yahoo.com

Regd. Office :

9 Shivranjani Shopping Centre on 132
Feet Ring Road, Near Shivranjani Cross
Road, Satelite Ahmedabad-380015
Tel. : 079-26762598, Email : info@ictaiapl.com

Site Office :

Hotel Iqbal, Near PDD Water Pond,
Kullan, Sonamarg,
Jammu & Kashmir - 191202
Email : zojila@ictaiapl.com